



NOTES:

1. THESE METHODS ARE TO BE USED WHEN INSUFFICIENT COVER EXISTS TO ALLOW PRESSURE PIPE TO CROSS ABOVE CONFLICT PIPE WITH 6" VERTICAL SEPARATION AND MAINTAIN REQUIRED COVER TO FINISHED GRADE.
2. FITTINGS SHALL BE RESTRAINED WITH RETAINER GLANDS.
3. THE DEFLECTION TYPE CROSSING IS PREFERRED.
4. DO NOT EXCEED 75% OF MANUFACTURER'S RECOMMENDED MAXIMUM JOINT DEFLECTION.

PRESSURE PIPE CONFLICT DETAIL

DSGN.	
DRW. MES	
CK. ML	



CONSTRUCTION STANDARDS AND DETAILS

DATE APPROVED
AUGUST 2016

DRAWING NUMBER

G 11