



**NOTES:**

1. CONCRETE PROTECTIVE SLAB SHALL BE 2500 P.S.I. WITH 6"x6"-10/10 W.W. MESH AND 12" MIN. BEARING EACH SIDE OF TRENCH.
2. PROTECTIVE SLAB REQUIRED WHERE COVER FOR MAINS IS LESS THAN 30" AND LATERALS WHEN LESS THAN 24".

# PROTECTIVE SLAB FOR PIPE

DSGN.	
DRW.	MES
CK.	ML



SOUTH MARTIN REGIONAL UTILITY (SMRU)

## CONSTRUCTION STANDARDS AND DETAILS

DATE APPROVED  
AUGUST 2016

DRAWING NUMBER

G 19