



NOTES:

1. ALL VALVES TO BE STRAIGHT 2" BALL VALVES WITH LOCK- WING. (FLANGE AT METER) FORD OR APPROVED EQUAL.
2. SEE TYPICAL SERVICE DETAIL FOR MAIN CONNECTION.
3. METER BOX SHALL BE POLYMER CONCRETE FIBER REINFORCED POLYESTER, AND "PURPLE" IN COLOR. (PANTONE 522)
4. PIPING SHALL BE 2" SCHEDULE 80 PVC WITH SCHEDULE 80 FITTINGS.
5. LID SHALL BE PURPLE AND MARKED "REUSE".

IQ RETAIL WATER SERVICE DETAIL, 2" METER

DSGN.	
DRW.	MES
CK.	ML



CONSTRUCTION STANDARDS AND DETAILS

DATE APPROVED	AUGUST 2016
DRAWING NUMBER	IQ 02