



NOTES:

1. ALL FLANGED PIPE AND FITTINGS SHALL BE DUCTILE IRON, CEMENT LINED.
2. MECHANICAL JOINT FITTINGS REQUIRED BELOW GRADE AND FLANGED FITTINGS FOR ABOVE GRADE USE.
3. ALL ABOVE GRADE MATERIAL SHALL BE COATED WITH A TWO PART EPOXY PAINT. COLOR SHALL BE PURPLE.
4. CONCRETE SUPPORTS SHALL BE INSTALLED AS SHOWN. ALL CONCRETE SHALL BE 3000 PSI.
5. ALL ABOVE GROUND BOLTING SHALL BE STAINLESS STEEL.
6. PIPE SHALL BE SIZED BY ENGINEER.
7. CONCRETE MONOLITHIC SLAB POURED TO FENCING.

IQ WATER METERING FACILITY (BULK USER)

DSGN.

DRW. MES

CK. ML



SOUTH MARTIN REGIONAL UTILITY (SMRU)

CONSTRUCTION STANDARDS AND DETAILS

DATE APPROVED

AUGUST 2016

DRAWING NUMBER

IQ 05