


THIS DRAWING DEPICTS A GENERAL SITE PLAN ONLY. THE ENGINEER OF RECORD SHALL COORDINATE THE SPECIFIC SITE PLAN REQUIREMENTS WITH SMRU



NOTES: (PLEASE REFER TO WRITTEN SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS)

1. COLLECTOR MANHOLE SHALL NOT BE PLACED IN TRAVEL LANE OR AREAS THAT WOULD LIMIT ACCESS.
2. LANDSCAPING SHALL BE A MINIMUM OF 2' FROM FENCE. TREE PLACEMENT AND LANDSCAPING SHALL BE APPROVED BY SMRU.
3. CONTRACTOR SHALL INSTALL PERMANENT FALL RESTRAINT ANCHOR SYSTEM AROUND WET WELL PER OSHA STANDARDS
4. ENGINEER TO PREPARE SITE PLAN TO SHOW ACTUAL DIMENSIONS AND ORIENTATION
5. ACCESS ROAD TO CONFORM TO MARTIN COUNTY ENGINEERING DETAILS FLEXIBLE PAVEMENT SECTION - LOCAL
6. OVERALL SLAB DIMENSIONS SHALL BE BASED ON MINIMUM CLEARANCES. CONTRACTOR TO VERIFY DIMENSIONS PRIOR TO CONSTRUCTION.

TYPICAL LIFT STATION SITE PLAN - DUPLEX

DSGN.	 SOUTH MARTIN REGIONAL UTILITY (SMRU)	DATE APPROVED June 2016
DRW. MS		DRAWING NUMBER
CK. ML		LS 1

CONSTRUCTION STANDARDS AND DETAILS