



PIPE SUPPORT DETAIL

NOTES:

1. ALL ABOVE GRADE PIPING SHALL BE BRASS. FITTINGS SHALL BE BRONZE.
2. ALL JOINTS SHALL BE THREADED.
3. FOR LIFT STATION TO BE OWNED BY SMRU USE RPZ BACKFLOW PREVENTER BY FEBCO MODEL 825Y, AMES SERIES 4000 SS (SILVER BULLET), OR APPROVED EQUAL.
4. MIN. 24" CLEARANCE BETWEEN RPZ BACKFLOW PREVENTER AND CONTROL PANEL REQUIRED.
5. THREADED AREAS OF CORPORATION STOP AND OTHER FITTINGS SHALL BE SPIRAL WRAPPED WITH TWO WRAPS OF TEFLON TAPE.

## WATER SERVICE DETAIL AT LIFT STATION

DSGN.

DRW. MES

CK. ML



SOUTH MARTIN REGIONAL UTILITY (SMRU)

CONSTRUCTION STANDARDS AND DETAILS

DATE APPROVED

JUNE. 2016

DRAWING NUMBER

LS 06