



NOTES:

1. COVER TO BE ALUMINUM DIAMOND PLATE, HINGED, TRAFFIC BEARING WITH POSITIVE LOCKING ARM AND LOCKING HASP.
2. MINIMUM COVER DIMENSIONS – – – 30"x 48", 15HP OR LESS, 48"x72" GREATER THAN 15 HP
3. COVER SHALL BE CAST IN PLACE (BILCO TYPICAL)
4. SPLIT COVER IS ACCEPTABLE FOR LARGER SIZES.
5. RECESSED HASP IS REQUIRED IN WALKWAYS AND TRAFFIC AREAS.
6. LID TO BE 300 PSF LOADING.
7. HANDLE TO BE SECURED BY STAINLESS STEEL NUTS.

LIFT STATION HATCH

DSGN.	
DRW.	MES
CK.	ML



SOUTH MARTIN REGIONAL UTILITY (SMRU)

CONSTRUCTION STANDARDS AND DETAILS

DATE APPROVED
JUNE. 2016

DRAWING NUMBER

LS 07