

PLEASE REFER TO WRITTEN SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS

LEGEND	NOMENCLATURE	MANUFACTURER	PART NUMBER
AL	ALARM LIGHT	FEDERAL SIGNAL	LP3P-120R
CCB	CONTROL BREAKER	SQUARE D	FAL 12###
CT1	CONTROL TRANSFORMER 480/120V	SQUARD D OR HEAVY DUTY	2000 VA
DR	DUPLEX RECEPTACLE (GFI)	HUBBELL	GFTR15SNAPWNA
DRB	RECEPTACLE BREAKER	SQUARE D	FAL 12015
ECB	EMERGENCY BREAKER	SQUARE D	THERMAL MAGNETIC MOLDED CASE
FB 1	FUSE X3	BUSSMAN-KTK	1 AMP WITH 600V FUSE BLOCKS
FB 2	FUSE X2	BUSSMAN-KTK	10 AMP WITH 600V FUSE BLOCKS
FB 2	FUSE	BUSSMAN-KTK	20 AMP WITH 250V FUSE BLOCK
F1 - F3	FUSE	BUSSMAN-MDL	1 AMP WITH 250V FUSE BLOCK
FS	FLOAT SWITCH	ANCHOR SCIENTIFIC	ROTO-FLOAT
GR1-GR1A	GEN RECEPT. W/ ANGLE	RUSSELLSTOLL	FEMALE RECEPTACLE W/ ANGLE ADAPTER 100A
GR2-GR2A	GEN RECEPT. W/ ANGLE	RUSSELLSTOLL	FEMALE RECEPTACLE W/ ANGLE ADAPTER 200A
LA	LIGHTNING ARRESTOR	DELTA	LA303 (250V) OR LA603 (480V)
MB	MOTOR BREAKER	SQUARE D	THERMAL MAGNETIC MOLDED CASE WITH AUX CONTACT
MCB	MAIN BREAKER	SQUARE D	THERMAL MAGNETIC MOLDED CASE
M	MOTOR STARTER	SQUARE D	8536 SERIES
OL	OVERLOADS	SQUARE D	MELTING ALLOY WITH SO-4 AUX CONTACT
TCU	TELEMETRY CONTROL UNIT	DATA FLOW SYSTEMS	
PM	PHASE MONITOR	DIVERSIFIED	SLA-XXX-ALE
SA	SURGE ARRESTOR	SQUARE D	SDSA3650
TB	TERMINAL BOARD	MARATHON	200 SERIES
GL	GROUND LUG-2 CONDUCTOR	THOMAS & BETTS	ADR 21-21
GL	GROUND LUG-SINGLE CONDUCTOR	THOMAS & BETTS	ADR 21
TCV	TCV SNAP-IN KIT	DATA FLOW SYSTEMS	DFS-00392-008-09
PP	POLYPHASER	DATA FLOW SYSTEMS	DFS-00392-008-01
RC	RC SNUBBER	DATA FLOW SYSTEMS	DFS-007-C084

LIFT STATION CONTROL PANEL MATERIAL LIST

DSGN.	 SOUTH MARTIN REGIONAL UTILITY (SMRU)	DATE APPROVED
		June 2016
DRW. MS	CONSTRUCTION STANDARDS AND DETAILS	DRAWING NUMBER
CK. ML		LS 11