



- NOTES:
1. 4-20mA INTERFACE SHOWN. REMOVE JUMPER FROM P2-24 TO P2-23 FOR 0-5V INTERFACE.
 2. SURGE ARRESTOR RECOMMENDED.
 3. ANALOG IS BOUNDED INTERNALLY TO ISOGND.
 4. THE ANALOG SHIELD WIRE MUST ONLY BE GROUNDED AT ONE END.
 5. INSTALL AS DIRECTED BY SMRU.

FLORIDA LICENSED PROFESSIONAL ENGINEER TO REVIEW AND MODIFY ELECTRICAL DESIGN AS REQUIRED TO ACCOMPLISH CONSTRUCTION IN ACCORDANCE WITH APPLICABLE CODES AND STANDARDS

Diaphragm Seal, Pressure Gauge & Transducer Installation

DSGN.	 SOUTH MARTIN REGIONAL UTILITY (SMRU)	DATE APPROVED
DRW. MS		June 2016
CK. ML		DRAWING NUMBER
CONSTRUCTION STANDARDS AND DETAILS		LS 12