



NOTES:

1. ALL VALVES TO BE STRAIGHT 2" BALL VALVES WITH LOCK-WING. (FLANGE AT METER) FORD OR APPROVED EQUAL.
2. SEE TYPICAL SERVICE DETAIL FOR MAIN CONNECTION.
3. METER BOX SHALL BE POLYMER CONCRETE AND FIBER REINFORCED POLYESTER.
4. PIPING SHALL BE 2" SCHEDULE 80 PVC WITH SCHEDULE 80 FITTINGS.
5. UTILITY PROVIDES AND INSTALLS METER. COORDINATE WITH UTILITY FOR PROPER METER SETTING LENGTH.

2" METER DETAIL

DSGN.

DRW. MES

CK. ML



SOUTH MARTIN REGIONAL UTILITY (SMRU)

CONSTRUCTION STANDARDS AND DETAILS

DATE APPROVED

AUGUST 2016

DRAWING NUMBER

WS 03