



ELEVATION

NOTES:

1. HYDRANTS SHALL BE INSTALLED PLUMB AND TRUE.
2. VALVES SHALL BE PLACED ADJACENT TO MAIN, AND TIED TO TEE.
3. ANCHOR TEES ARE REQUIRED.
4. ALL HYDRANTS SHALL BE TEE'D OFF OF MAIN.
5. HYDRANTS SHALL NOT BE PLACED IN SIDEWALK, ROADWAYS OR BIKEPATHS.
6. PIPE FROM VALVE TO HYDRANT SHALL BE RESTRAINED.
7. HYDRANT BARREL COLOR TO BE OSHA YELLOW AND BONNET OSHA WHITE.
8. THE CONNECTOR PIPE SHALL BE CEMENT LINED DUCTILE IRON, CLASS 350 AND POSITIONED BETWEEN THE FIRE HYDRANT AND GATE VALVE.
9. THE CONNECTOR PIPE SHALL HAVE AN ANCHORING FEATURE AT BOTH ENDS SO THAT WHEN USED WITH M.J. SPLIT GLANDS A RESTRAINED JOINT IS PROVIDED.
10. HYDRANT EXTENSIONS SHALL NOT BE ALLOWED.
11. NEWLY CONSTRUCTED FIRE HYDRANTS THROUGHOUT THE PROJECT SHALL HAVE A RED "OUT OF SERVICE" DISK (JOSEPH G. POLLARD CO. OR EQUAL) ATTACHED TO 6" PUMPER NOZZLE CAP. DISK TO BE REMOVED AFTER WATER SYSTEM HAS BEEN APPROVED FOR SERVICE BY THE DEPARTMENT.

**FIRE HYDRANT INSTALLATION
DETAIL AND NOTES**

DSGN.	
DRW.	MES
CK.	ML



CONSTRUCTION STANDARDS AND DETAILS

DATE APPROVED
AUGUST 2016

DRAWING NUMBER

WS 06