



NOTES:

1. AN AIR GAP SEPARATION MEANS THE UNOBSTRUCTED VERTICAL DISTANCE THROUGH THE FREE ATMOSPHERE BETWEEN THE LOWEST OPENING FROM ANY PIPE OR FAUCET SUPPLYING WATER TO A TANK, PLUMBING FIXTURE OR OTHER DEVICE AND THE FLOOD LEVEL OR OVERFLOW RIM OF THE RECEPTACLE.
2. THE "APPROVED AIR GAP SEPARATION" SHALL BE AT LEAST DOUBLE THE DIAMETER OF THE SUPPLY PIPE MEASURED VERTICALLY ABOVE THE OVERFLOW RIM OF THE VESSEL AND IN NO CASE SHALL THE GAP BE LESS THAN ONE (1) INCH IN DIAMETER.

AIR GAP SEPARATION

DSGN.	
DRW.	MES
CK.	ML



CONSTRUCTION STANDARDS AND DETAILS

DATE APPROVED	AUGUST 2016
DRAWING NUMBER	WS 13