



- NOTES:
1. FLUSHING HYDRANT ASSEMBLY SHALL BE GIL INDUSTRIES, AQUARIUS ONE-O-ONE 2" POST FLUSHING HIDDEN HYDRANT.
 2. MAIN TO BE RESTRAINED FOR THREE FULL LENGTHS.

MANUAL POTABLE WATER FLUSHING HYDRANT

| | |
|-------|-----|
| DSGN. | |
| DRW. | MES |
| CK. | ML |



CONSTRUCTION STANDARDS AND DETAILS

| | |
|----------------|-------------|
| DATE APPROVED | AUGUST 2016 |
| DRAWING NUMBER | WS 14 |